

SCM-4825 Technical Information:
☐ Power Requirements: 120V, 60Hz, 15A dedicated grounded circuit required.



1 **FIRST FLOOR**
SCALE: 1/16" = 1' 0" 0 1' 2"



2 SECOND FLOOR
SCALE: 1/16" = 1' 0" 0 1' 2' 4'



LL LOWER LEVEL
SCALE: 1/16" = 1' 0" 0' 2"

MAP KEY

Shelter Locations

- Primary
- Secondary

FOUR FEATHERS ALARM, LLC DBA TEXAS FFA, LLC
3621 POTTSBORO RD #137 DENISON, TX 75020 PHONE 903-818-4233

FIRE ALARM
FIRE SPRINKLER/SUPPRESSION
TX LIC# SCR-G-2197396
TX LIC# ECR-2201181
OK LIC# RME-G-0270

TX LIC# B16154 ACR3336
AR LIC# E 2012 0032

FIRE ALARM PLAN

304 ADMINISTRATION
DR.
DENTON, TX 76204



FIRE&SECURITY
888-899-7258
TX LIC#SCR-G-2197356
AR LIC# E 2012 0032
OK LIC# 1847

NATIONAL FIRE
ALARM CODE
NFPA 72 2016

INFO@
FOURFEATHERSALARM.COM

SCALE: 0-1/16" = 1'
PROJECT
RACKENRIDGE HALL- A01
304 ADMINISTRATION DR.
DENTON, TX 76204

DRAWN BY
DAE
REV. DATE
02/14/25
DRAWING NUMBER
AREA OF
RESCUE
FP-100
REV. 1